



NOTICE TO ALL CONTRACTORS

May 28, 2008

BONDING OF INTERIOR GAS PIPING

Rule 10-406 Non-electrical Equipment

For the gas pipe bonding requirements in single dwellings, the bonding conductor supplied as an integral part of a cable assembly supplying the appliance may be considered a suitable bonding conductor for the circuit supplied by that cable assembly and may be deemed to meet the intent of Subrule 10-406(4)