



NOTICE TO ELECTRICAL CONTRACTORS

February 26, 2007

ELECTRICAL PLANS REVIEW

The following types of electrical installations in the NWT require that the plans review process be completed **before the start** of any work:

- ***All Buildings used for Multi-Family Residential Units***
- ***All Buildings used for Commercial Tenants***
- ***All Buildings used for Industrial Installations of Any Type***

Electrical plans on any project with a consumer's service in which the rating of the consumer's service exceeds 400 amps single phase or 200 amps three-phase **must** be stamped as approved by a P.Eng who has a current membership in NAPEGG (Association of Professional Engineers, Geologists & Geophysicists of the N.W.T. & Nunavut).

Canadian Electrical Code, Rule 2-014, Clause C, gives the inspection department the mandate to determine which electrical installations must be included in the Electrical Plans Review process.